

Certificate of Product Approval

Certificate Number: 928aj (cl-1)

Issue: 02

Hyfire Wireless Fire Solutions Limited

Unit B12a, Holly Farm Business Park
Honiley
Warwickshire
CV8 1NP
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi Criteria Devices

HFV-TRI-05

(refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018

EN 54-7:2018

EN 54-25:2008

EN 54-31: 2014 + A1: 2016

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan

Signed for BRE Global Ltd

Verifier

5 September 2022

Date of Issue

8 April 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 928aj (cl-1)

Issue: 02

Hyfire Wireless Fire Solutions Limited

Certified Product	Description	LPCB Ref.No.
HFw-TRI-05	<p>Wireless Addressable Multi Criteria Smoke, Heat and CO Detector. (WAB100 Base)</p> <p>Notes:</p> <ol style="list-style-type: none"> Meets the requirements of EN 54-31 and EN 54-5 depending on the specific classification setting at classes A1R and BS. Meets the requirements of EN 54-31 and EN 54-7 at all classification settings. <p>Classification Settings:</p> <p>L0 – Harsh smoke profile; smoke profile number 0; heat classification BS. L1 – Harsh smoke profile; smoke profile number 1; heat classification A1R. L2 – Harsh smoke profile; smoke profile number 2; heat classification A1R. L3 – Harsh smoke profile; smoke profile number 3; heat classification A1R. N0 – Normal smoke profile; smoke profile number 0; heat classification A1R. N1 – Normal smoke profile; smoke profile number 1; heat classification A1R. N2 – Normal smoke profile; smoke profile number 2; heat classification A1R. N3 – Normal smoke profile; smoke profile number 3; heat classification A1R. H0 – Clean smoke profile; smoke profile number 0; heat classification A1R. H1 – Clean smoke profile; smoke profile number 1; heat classification A1R. H2 – Clean smoke profile; smoke profile number 2; heat classification A1R. H3 – Clean smoke profile; smoke profile number 3; heat classification A1R.</p>	928aj/01

Base:

WAB100 Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

5 September 2022

Date of Issue

8 April 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

