

Certificate of Product Approval

Certificate Number: 928c-(cl-9)

Issue: 03

Hyfire Wireless Fire Solutions Limited

Unit B12a, Holly Farm Business Park
Honiley
Warwickshire
CV8 1NP
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi-Sensor/Multi-Criteria Detectors

HFI-MA-05

(refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018

EN 54-7:2018

EN 54-17:2005

CEA 4021: 2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan

Signed for BRE Global Ltd

Verifier

5 September 2022

Date of Issue

28 October 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Hyfire Wireless Fire Solutions Limited

Certified Product	Description	LPCB Ref.No.
HFI-MA-05	<p>Addressable Multi-Criteria Detector with Short-Circuit Isolator (HFI-DMBS-05 Base)</p> <p>Notes:</p> <ol style="list-style-type: none"> Meets the requirements of EN 54-5 (Category A1) & EN 54-7 at the following settings: <ul style="list-style-type: none"> Multi Criteria Level 1 (most sensitive) - Thermally enhanced smoke detection with Category A1 heat response Multi Criteria Level 2 - Thermally enhanced smoke detection with Category A1 heat response Multi Criteria Level 3 - Thermally enhanced smoke detection with Category A1 heat response Multi Criteria Level 4 (least sensitive) - Thermally enhanced smoke detection with Category A1 heat response Meets the requirements of EN 54-5 (Category A1R) at the following settings: <ul style="list-style-type: none"> Category A1R heat only response Meets the requirements of EN 54-7 at the following sensitivity settings: <ul style="list-style-type: none"> Optical only level 1 - High Optical only level 2 Optical only level 3 Optical only level 4 - Low 	928c/02

Bases

HFI-DMBS-05 Low Profile Adaptor Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

5 September 2022

Date of Issue

28 October 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

