

Certificate of Product Approval

Certificate Number: 928K-(cl-6) Issue: 05



Unit B12a, Holly Farm Business Park Honiley Warwickshire CV8 1NP United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Smoke DetectorsHFW-PA-05
ROP-E
(Refer to Appendix for details)

Standards

EN 54-7:2018 EN 54-25:2008

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



P Halligan

Verifier

5 September 2022

25 August 2011

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.







Appendix to Certificate No: 928K-(cl-6)

Issue: 05

Hyfire Wireless Fire Solutions Limited

Certified Product	Description	LPCB Ref.No.
HFW-PA-05	Wireless Libra Addressable Optical Smoke Detector (WAB100 Base) Notes:	928k/02
	 1 Meets the requirements of EN 54-7 at the following sensitivity settings: Level 1 – High Level 2 – Normal Level 3 – Low 2 The device must be used with the following battery type only: 	
	- CR123A (3 Vdc) – Primary and Secondary Battery	
ROP-E	Wireless Addressable Optical Smoke Detector (WAB100 Base) Notes: 1 Meets the requirements of EN 54-7 at the following sensitivity settings: Level 1 – High Level 2 – Normal Level 3 – Low 2 The device must be used with the following battery type only:	928k/02
	- CR123A (3 Vdc) – Primary and Secondary Battery	

Bases

WAB100 Wireless Adaptor Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



P Halligan

Verifier

5 September 2022 Date of Issue 25 August 2011

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 E: <u>enquiries@breglobal.com</u>

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



